

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 389

Dated: 11.10.2023


It is certified that an inspection team headed by Saurabh Kumar Singh (Myself), A E

(Name of Officers with designation) from PHED, Biharsharif

(Name of Department/ Office) inspected the Chanakya Convent School, Kewai, Tiyari More

Dahpar, Nalanda  
(Name & Address of the school) on 10.10.23 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

Signature with Seal: 

Name : SAURABH KUMAR SINGH

Designation : ASSISTANT ER  
**SAURABH KR. SINGH**

Assistant Engineer of SDO  
the Govt. Public Health Department (PHED),  
Authorised officer of the Local Body  
**P.H. SUB. DIVISION**  
**BIHAR SHARIF**

Name & Address of the Office / Department : .....

PHED, BIHARSHARIF  
NALANDA

To

CHANAKYA CONVENT  
SCHOOL, KEWAI,  
TIYARI MORE, DAHPAR  
NALANDA  
(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**Government of Bihar**  
**Public Health Engineering Department**  
**Water Quality Report**

<b>District Name: Nalanda</b>		<b>Division Name: Public Health Engineering Division, Biharsharif</b>																		
Sample Collected by : -Mahendra Kumar Sinha		Date of Sampling :- 06/10/2023																		
Sl. No.	Block	Panchayat	Village	Location of Source	Test result											Source of Water				
1	2	3	4	7	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	T.Coli		
2	Noorsarai	Nadiyauna	Kewai	Chanakya Convent School Kewai	8	0.65	780	510	240	40	14	50	260	0.14	0.561	6.9	0.768	<1.1		Tubewell
Desirable Limit* 6.5-8.5						1	-	500	200	75	30	250	200	1	45	200	1	-		
Permissible Limit* in absence of alternate source					NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	**		

*Rajesh Kumar*  
Chemist 10/10/2023  
Public Health Division, Biharsharif  
( Nalanda )